



SCALE 0.015

NOTES:

1. MATERIAL CARBON STEEL.
2. SILENCER IS DESIGNED TO SUPPORT OWN WEIGHT ONLY.
3. STANDARD MAXIM CONSTRUCTION TOLERANCE APPLY ( $\pm 1/4"$ ).
4. ALL WELDED CONSTRUCTION.
5. DRAWING SUBJECT TO CHANGE WITHOUT NOTICE.

REV. NO.	REV. BY	MM/DD/YY	DATE	DESCRIPTION
XX	XX	MM/DD/YY	DATE	XXXXXXXXXXXXXXXX
ALL DIMENSIONS IN INCHES UNLESS OTHERWISE SPECIFIED.				DRAWING TYPE: SALES
TOLERANCES APPLY ON CRITICAL DIMENSION(S) AS SHOWN BELOW: $\pm 1/4"$ IMP FRAC; $\pm 0.25$ IMP DEC $\pm 0.35$ MM METRIC; $\pm 2^\circ$ ANGULAR				DRAWN BY: BP
DIM HOLD - CRITICAL DIMENSION				DATE: 10/6/17
THE INFORMATION HEREIN IS THE PROPERTY OF MAXIM SILENCERS. TRANSMITTAL TO OTHERS OR USE EXCEPT THAT FOR WHICH IT IS PROVIDED IS STRICTLY PROHIBITED. DO NOT SCALE DRAWING.				APPROVED BY: DATE:
THIRD ANGLE PROJECTION				TITLE: HOCKEY PUCK HOSPITAL, ICE INSULATED
REF #:	EST. WEIGHT:	MAXIM MODEL NO.:	DRAWING NO.:	REV:
08	3359 LBS	MD52-18C1-S	STANDARD	00
ORDER:	SHIP DATE:	PROJECT/SALES ORDER NO.:	EXTERNAL FINISH:	SHEET:
			HT BLACK PAINT	1 OF 1



10635 Brighton Lane  
Stafford, TX 77477  
PH (832) 554-0980  
FX (832) 554-0990  
www.maximsilencers.com