



NOTES:

1. MATERIAL CARBON STEEL.
2. SILENCER IS DESIGNED TO SUPPORT OWN WEIGHT ONLY.
3. STANDARD MAXIM CONSTRUCTION TOLERANCE APPLY ($\pm 1/4$ ").
4. ALL WELDED CONSTRUCTION.
5. DRAWING SUBJECT TO CHANGE WITHOUT NOTICE.

REV. NO.	REV. BY	MM/DD/YY	DATE	DESCRIPTION
XX	XX	MM/DD/YY	DATE	XXXXXXXXXXXXXXXX
ALL DIMENSIONS IN INCHES UNLESS OTHERWISE SPECIFIED.				DRAWING TYPE: SALES
TOLERANCES APPLY ON CRITICAL DIMENSION(S) AS SHOWN BELOW: $\pm 1/4$ " IMP FRAC; ± 0.25 IMP DEC ± 0.35 MM METRIC; $\pm 2^\circ$ ANGULAR				DRAWN BY: BP
DRAWING TYPE: SALES				DATE: 10/6/17
DRAWN BY: BP				DATE: 10/6/17
APPROVED BY:				DATE:
TITLE: HOCKEY PUCK HOSPITAL, ICE INSULATED				
REF #: 08		EST. WEIGHT: 3864 LBS		MAXIM MODEL NO.: MD52-20C1-SB
DRAWING NO.: STANDARD		REV: 00		
THIRD ANGLE PROJECTION		ORDER:	SHIP DATE:	PROJECT/SALES ORDER NO.:
		EXTERNAL FINISH: HT BLACK PAINT		SHEET: 1 OF 1



10635 Brighton Lane
Stafford, TX 77477
PH (832) 554-0980
FX (832) 554-0990
www.maximsilencers.com